


NOTES:

1. NEW FLASHINGS MUST EXTEND VERTICALLY A MINIMUM OF 8". SEE CHART FOR FLASHING LENGTH REQUIRED UP SLOPED ROOF.
2. SHINGLE UNDERLAYMENT MUST EXTEND MINIMUM 2" OVER TOP OF PVC FLASHING.
3. PVC FLASHING MUST EXTEND UP UNDER AT LEAST TWO COURSES OF SHINGLES.

SHINGLE SLOPE	FLASHING LENGTH UP SLOPE
3:12	33"
4:12	25"
5:12	21"
6:12	18"
7:12	16"
8:12	14"
9:12 AND HIGHER	12"



TRITON

TRITON PVC
TIE-IN AT SHINGLE ROOF
(NOT TO SCALE)

DETAIL NUMBER

PVC-UN-604